


OUTDOOR PIR MOTION DETECTOR for Lighting or HVAC Automation Control KDP24 GS32



INSTRUCTION MANUAL

TECHNICAL SPECIFICATIONS

Rated Voltage	220-240V~ 50/60Hz
Load	<p>For lighting (with jumper wire) ⚡ Incandescent lamp: Max. 2300W AC Halogen lamp : Max. 1200W LV Halogen lamp : Max. 1000VA / 600W (Conventional) Max. 900W (Electronic) Fluorescent lamp : Max. 1000VA / 600W (uncompensated) Max. 900VA / 100μF (compensated) LED lamp(Driver) : Max. 400W Energy Saving : Max. 600VA / 400W lamp (include CFL and PL lamp) For HVAC (remove jumper wire) Max.10A(cos φ = 1) for ≤ 250VAC Max.5A for ≤ 30VDC Max.3A(cos φ = 0.4) for ≤ 250VAC</p>
Detection Range	240°, up to R1.6m (frontal)/R8m(backward) at height of 2.5m
Auto Off Time Adjustment	Adjustable from approx. 5sec to 30min and Test & JISL
Lux Adjustment	Adjustable from approx. 5Lux to "∞" (∞) and "☀" (learning range: 5Lux - 500Lux) & Holiday
Operating Temperature	-20°C to +50°C
Environmental Protection	IP55 (wall mount) IP54 (ceiling mount)

Installation and assembly of electrical equipment must be carried out by qualified electricians. Contact a qualified electrician in the event of fault or break down.

CAUTION!

- A circuit breaker (250VAC, 10A) type C according to EN60898-1 of load shall be installed in the fixed wiring for protection.
- Do not mount on conductive surface.
- Do not open the enclosure frequently.
- Turn off power when change the light sources.
- High in-rush current would be caused when bulbs of certain brands burned which might damage the unit permanently.
- The sensor works with warm up function to switch on the connected load 60 sec after power is supplied, it will turn off the load after 60 sec, and turn on again if the sensor is triggered after warm-up.

1 PACKAGE CONTENTS

Pattern	Item	Quantity
	Motion detector	1
	Lens shield	2

Pattern	Item	Quantity
	Rubber washer	2
	Wood Screw Φ4x25.4mm	2
	Anchor	2
	Manual	1

● Accessories for optional purchase




Pattern	Item	Quantity
	Corner mounting bracket	1
	Wood Screw Φ4x10mm	2

2 PRODUCT DESCRIPTION

- ### 2.1 Features
- Can be used to control lighting or HVAC devices (voltage free contact).
 - Pulse count function to avoid the false triggering problem caused by environment.
 - Excepting the provided Lux values, the ambient light level can be read-in as the Lux value for more flexible application.
 - Manual override for lighting on 8hrs. is enabled by using an external rocker switch to control or IR remote control.
 - Built-in 4 LEDs provide Warning / Watch function, which enables the detector to guarantee complete surveillance or warning respectively.
 - User friendly design of un-falling mounting base and plug-in terminal block for installation convenience.

- The unique holiday mode for randomly switching ON / OFF load is worked as a simple security function to protect your property.
- The IR remote control is available for quick and convenient setting (for optional purchase).

2.2 Dimension (See FIG.1-A & FIG.1-B & FIG.1-C)





3 INSTALLATION AND WIRING

⚠ Please disconnect power completely and read the entire instruction manual carefully before installation.


3.1 Select a proper location

- 3.1.1 It is recommended to install the detector at the height of 2.5m. The detection range can reach up to a radius of 1.6m at the height of 2.5m (See FIG.2-A & FIG.2-B).




3.1.2 Helpful tips for installation

- 3.1.2.1 The optimal location for installation is at garden, corridor, staircase, entrance, garage, public lavatory, outdoor parking area, home and office, etc.
- 3.1.2.2 Since the detector responds to temperature change, please avoid the following conditions:
- Avoid pointing the detector toward the objects whose surfaces are highly reflective, such as mirror, glass, etc.
 - Avoid mounting the detector near heat sources, such as heating vents, air conditioners, lights, etc.
 - Avoid aiming the detector toward the objects which may be swayed in the wind, such as curtain, tall plants, etc.



3.1.2.3 Pay attention to the walking direction in the test proceeding (See FIG.4).



3.2 Function

- #### 3.2.1 Auto mode
- Under Auto mode, the load will turn on automatically when the movement is detected and the ambient light level is below the Lux setting value. When no movement is detected and the delay time has expired, the load will turn off automatically.

3.2.2 Manual override for switching light on for 8 hours (Lux is independent)

When detector is standby under the auto mode, the detector can be bypassed to turn the light(s) on for 8 hours by series connecting a power supply switch.

The operations are as under mentioned :


- When the light is off, transfer the power supply switch from "off → on → off → on" within 2sec, afterwards, light will change its status from on 3sec & off 2sec & on to confirm that detector has entered into permanent on 8 hours mode.
- When the light is on, transfer the power supply switch "off → on → off → on" within 2sec, afterwards, light will turn off for 2sec, then turns on to confirm that detector has entered into permanent on 8 hours mode.
- In the permanent on 8 hours mode, the detector can be set to auto mode by transferring the power supply switch "off → on" within 1 sec, afterwards, light will turn off for 2sec. then detector enters into auto mode and work with the knob settings.

3.2.3 Holiday function


- Set the Lux knob to "Holiday" position, LED will flash quickly for 10sec, and then keep on for 10min to 1hr for the next 4hrs. When the load is off, LED will flash by turns. When the load is on, the 4 LEDs will flash simultaneously under this mode.
- Under Holiday mode, the light will turn on automatically when the ambient light level is below 50 Lux. Then the light will randomly turn ON and OFF between 10min to 1hr for the next 4hrs. When the load is off, LED will flash by turns. When the load is on, the 4 LEDs will flash simultaneously under this mode.
 - Exit Holiday mode: During the Holiday mode, adjust the Lux knob to other positions beside "Holiday", load will turn off and LED will flash for 5sec to indicate detector exiting Holiday mode.

3.3 Wiring diagrams



3.3.1 Normal operation for lighting control (See FIG.5)



3.3.2 Staircase timer switch controlled by one sensor (Time should be set to JISL (See FIG.6).



3.3.3 For HVAC control (See FIG.7)







3.4 Installation procedure




This outdoor motion detector can be installed on wall directly & recess corner with mounting bracket or on the ceiling directly on the European standard junction box.

3.4.1 Wall mount and ceiling mount

- 3.4.1.1 When installing, the junction box of detector can be stuck on the bottom cover by inserting the hook into the slot, so that you don't need to hold the product on hand, to make installation conveniently (See FIG.9-A & FIG.9-B & FIG.9-C).
- 3.4.1.2 Please strip off 6-8mm of cables sheathing by tool before installation.
- 3.4.1.3 Feed the electric cables through rubber gasket (see FIG.8) and refer to illustration of FIG.5 - FIG.7 for correct wiring, then fit the bottom cover on the wall or ceiling firmly by two screws (See FIG.10).






- 3.4.1.4 Fix the detector head to the bottom cover (See FIG.11) and adjust the detector head to be in the right position (See FIG.12-A & FIG.12-B).





3.4.2 Corner / recess mount with mounting bracket

- 3.4.2.1 There are cable entry knock-outs at back and bottom sides. Select the proper holes and break it through for wiring. (See FIG.14-B & FIG.14-C)




- 3.4.2.2 Break the desired screw knock-outs (See FIG.14-A). Then fix the mounting bracket onto recess/conner with wood screws (See FIG.15-A& FIG.15-B), and fix bottom cover on mounting bracket (See FIG.16). Refer to FIG.5-FIG.7 to connect power cables, then fix the detector head to the bottom cover and adjust the detector head to be in the correct position.



4 OPERATION AND FUNCTION

4.1 Time, Meter, Lux, Watch knob

Knob	Function	Knob setting
	Set delay off time of load	Range: Adjustable from approx. 5sec to 30min Test : Test mode (Load and red LED will be 2sec on, 2sec off) ⌚ : Short impulse mode for staircase timer switch control (Load will be 1sec on, 9sec off)
	Set the detection range	Range: Adjustable from approx. "r" (r=3m) to "+" (r=16m)
	Set the light value for switching on load and holiday function	Range : Adjustable from approx. 5Lux to "∞" (∞). ☞ (learn): The actual ambient light level (5-500Lux) can be read in. Holiday: The load will randomly turn on/off for the time of 10min to 1hr. in 4hrs.
	Set LED alert function	ON: Activate LED alert function. OFF: Deactivate LED alert function



Detector switches to AUTO mode
FIG. 18-C

NOTE

When the actual light level is out of the range 5 - 500Lux, detector will learn 25sec, then the red LED flashes quickly for 5sec. When the actual light level is below 5Lux, Lux value is set to 5Lux, or is above 500Lux, Lux value is set to ∞ (uncontrolled by Lux setting). Installer should be away from the detector to avoid affecting the luminous flux that reaches the detector when learning Lux value.

4.3 LED watch function

4.3.1 When the watch knob is set to either "ON" or "OFF" and Time knob is set to "Test", once the detector detects movement, only one LED of the 4pcs built-in red LEDs will turn on for 2sec. then turn off. If the detector detects movement continuously, the red LED will turn on for 2sec. and turn off 2sec. repeatedly which is uncontrolled by Lux setting until no movement is detected.

Time setting	Watch mode	Reaction of LED and Load	Lux control
Test mode	Watch ON/OFF	Load OFF LEDs do not action	Load 2sec on, 2sec off for indication Uncontrolled by Lux.
Time	Watch ON/OFF	LEDs do not action	The second LED 2sec on, 2sec off for indication

4.3.2 Set Watch knob to "ON" and Time knob to the other position the LED watch function is activated. In this mode, the 4pcs built-in red LEDs will work as described in below table. However, the aforesaid watch function is carried out only when Time knob is **not** set to "Test", please note.

Time setting	Watch mode	Reaction of LED and load	Lux control	
Not Test mode	Watch ON/OFF	Detector: Load OFF. LEDs flash by turns.	Detector: to be triggered Load: ON. 4pcs LEDs are flashing quickly for 5sec.	Controlled by Lux.
		Detector: Load OFF. LEDs no action	Detector: to be triggered Load: ON. LEDs no action	

4.3.3 Set the Watch knob to OFF position, the LED watch function is disabled and the 4pcs built-in red LEDs keep be off, excepting the Time knob is set to "Test" position which the LED will function as described in 4.3.1 under this condition.

4.4 Walk test (Lux setting is invalid)

It takes approx. 60sec for detector to warm up after power is supplied, then it enters into normal operation mode to carry out a walk test.

The purpose of walk test is to select a proper location and gain the desired detection coverage. Please set Time knob to "Test" and Meter knob to "+", then refer to the following steps conducting a walk test.




FIG. 19

● Walk test procedure

- 4.4.1 Tester must be within detection coverage.
- 4.4.2 Switch on the power.
- 4.4.3 KDP24 GS32 takes approx. 60sec to warm up with load and red LED turning on, then turns off after warming up time.
- 4.4.4 Walk from outside across to the detection pattern until red LED and load turn on for approx. 2sec, then turn off, the next trigger should be 2sec interval (See FIG. 19).
- 4.4.5 Adjust detector head aiming to the direction to be detected (See FIG. 13-A & FIG. 13-B).
- 4.4.6 Adjust Meter knob to reach desired coverage.
- 4.4.7 Adjust Time knob to change the switch off delay time.
- 4.4.8 Refer to point "4.5 Usage of lens shield", detection range and angle can be changed by using lens shield.
- 4.4.9 Repeat the steps 4.4.4 to 4.4.7 until it meets user's demands.

NOTE

- Do not attempt to open or repair the unit without qualified electrician while it is malfunctioned.
- The following conditions may cause lower sensitivity:
 - In very foggy days, the sensitivity may be less due to moisture collecting on the lens.
 - In very hot days, the sensitivity may be less since high ambient temperature is close to body temperature.
 - In very cold days when heavy clothing is dressed, especially the facial area is covered, very little heat will be emitted from the body causing the unit to be less sensitivity.
 - Cleaning: Wipe with dry cloth only. Soap or rough cloth may damage the detector lens.

4.5 Usage of lens shield

This motion detector can use lens shields for masking the undesired detection area. KDP24 GS32 has 2pcs lens shields. Each lens shield has 2 layers (layer A / layer B), each layer includes 13 small segments and each small segment can cover 8.5° detection angle. For example to install the detector at the height of 2.5m, the detection range is a diameter of approx. 10m (look down lens) if the complete lens shields have been used, and up to 14m diameter if only the layer A of lens shield has been used, and up to 32m diameter if no lens shield has been used. (See FIG. 20-A & FIG. 20-B)




FIG. 20-A




FIG. 20-B

● The shadow part of the lens shields in the FIG. 20-A & FIG. 20-B are referring to the cutoff parts.

4.5.1 Fixing lens shield: Take off the decorative frame of the detector head and insert the lens shield into the slot of decorative frame as following illustration (See FIG. 21 & FIG. 22). Then put the decorative frame back to the right position of the detector head.




FIG. 21




FIG. 22

5 TROUBLE SHOOTING

When KDP24 GS32 works abnormally, check assumptive problems and suggested solutions in following table that will hopefully solve your problem.

Problem	Possible cause	Suggested Solution
Lighting device does not turn on	1. Power does not turn on. 2. Wired incorrectly. 3. Lux knob adjusted incorrectly. 4. Malfunctioned load.	1. Switch on the power. 2. Refer to wiring diagrams for correct connection. 3. Check if Lux knob is set to the correct position. 4. Replace the disabled load with a new one.
Lighting device does not turn off	1. Auto off time is set too long. 2. Detector is nuisance triggered. 3. Wired incorrectly.	1. Set auto off time to a shorter time and check if the load is switched off or not according to the pre-set off time. 2. Keep away from detection coverage to avoid activating detector while doing the test. 3. Refer to wiring diagrams for correct connection.
LED does not turn on	1. Exceeding the detection range. 2. No power supplied. 3. Wired incorrectly.	1. Walk in the effective detection range 2. Switch on the power. 3. Refer to wiring diagrams for correct connection.
Nuisance triggered	There are heat sources, highly reflective objects or any objects which may be swayed in the wind within the detection coverage.	Avoid aiming the detector towards any heat sources, such as air conditionings, electric fans, heaters or any highly reflective surfaces. Make sure there are no swaying objects within the detection coverage.

GARANTÍA/GUARANTEE/GARANTIE 3 años/años/years/années

E- T.E.I. garantiza este aparato por 3 años ante todo defecto de fabricación. Para hacer válida esta garantía, es imprescindible presentar el ticket o factura de compra.
P- T.E.I. garantiza este aparelho contra defeitos de fábrica ate 3 anos.
F- T.E.I. garantit cet appareil pour le durée de 3 années contre tout défaut de fabrication.
GB- T.E.I. guarantees this device during 3 years against any manufacturing defect



TEMPER ENERGY INTERNATIONAL, S.L.
Polígono industrial, Nave 18
E-33199 Granda-Siero (Asturias) España
Teléfono: +34 985 793 204
Fax: +34 985 986 341
Email: info@grupotemper.com

Una empresa del grupo




FIG. 16

3.4.3 Wall / ceiling mount with European standard junction box

3.4.3.1 Pull out AC power cables from European standard junction box (See FIG. 17-A) then strip off 6-8mm of cable sheathing for wiring.




FIG. 17-A

3.4.3.2 Feed the electric cables through rubber gasket (See FIG. 8) and refer to FIG. 5 - FIG. 7 for correct wiring. Then fit the bottom cover on the European standard junction box firmly by two screws (See FIG. 10 - FIG. 17-B).




FIG. 17-B

3.4.3.3 Fix the detector head to the bottom cover (See FIG. 10) and adjust the detector head to be in the correct position.




FIG. 18-A




FIG. 18-B